

**To:** Daly, Eric[Daly.Eric@epa.gov]  
**From:** Kevin Shaver  
**Sent:** Fri 5/13/2016 2:05:03 PM  
**Subject:** RE: HTC-5374 Roberts Street

ok

**From:** Daly, Eric [mailto:Daly.Eric@epa.gov]  
**Sent:** Friday, May 13, 2016 10:02 AM  
**To:** Kevin Shaver <kshaver@gesoncall.com>  
**Subject:** RE: HTC-5374 Roberts Street

We are not going to have those specifics from our survey work. I could ask the home owner but I think we will need to make that determination on the 24<sup>th</sup>.

**From:** Kevin Shaver [mailto:kshaver@gesoncall.com]  
**Sent:** Friday, May 13, 2016 9:50 AM  
**To:** Daly, Eric <Daly.Eric@epa.gov>  
**Subject:** RE: HTC-5374 Roberts Street

Do we have a floor plan of the rest of the house? They requested that as they try to give the owner the option of running that pipe up through the roof instead of the exterior walls.

**From:** Daly, Eric [mailto:Daly.Eric@epa.gov]  
**Sent:** Friday, May 13, 2016 9:45 AM  
**To:** Kevin Shaver <kshaver@gesoncall.com>; Daniel Johnson <djohnson@gesoncall.com>; Richard Cole <rcole@gesoncall.com>  
**Subject:** HTC-5374 Roberts Street

Figure attached.

Good Morning:

Below are the answers to the radon system installer. I have attached a basic footprint map of the basement. However, Peter will be providing us a map with measurements shortly.

- Basement is all concrete
- Sump is concrete with drain tile in floor draining to sump area
- Basement has been dry
- There is no gaps between basement flooring and upright walls
- There are a few settlement cracks that exists in floor and walls
- No Radiant heat in flooring in basement
- The new addition/family room is built on a surrounding footer on 2x12 floor joists

Regards,

Eric

"We must, indeed, all hang together, or assuredly we shall all hang separately", Benjamin Franklin

Eric M. Daly

On-Scene Coordinator/Radiological Response Specialist  
US Environmental Protection Agency- Region II

ERRD/RPB/PPS  
2890 Woodbridge Avenue  
Edison, NJ 08837  
[daly.eric@epa.gov](mailto:daly.eric@epa.gov)  
732-321-4350